


THREADED & FSW ENDS					FLANGED END												
SIZE	MAT'L	DIMENSIONS, INCHES				WGT. LBS.	SIZE	ANSI FLANGE	DIMENSIONS, INCHES				WT. lbs.				
		A	B	C	D				A ₁	B	C	D					
1/2 & 3/4"	DV/BRZ	3.62	8.50	1.69	5.12	10	150#	DV/BRZ	CS/SS	7.25	7.25	8.50	8.50	1.69	5.12	13	15
	CS/SS	3.62	8.50	1.69	5.12	12		300#	7.50	7.50	8.50	8.50	1.69	5.12	14	16	
1"	DV/BRZ	4.12	10.00	2.62	7.09	21	150#	DV/BRZ	CS/SS	7.25	7.25	8.50	8.50	1.69	5.12	14	16
	CS/SS	4.18	10.75	2.62	7.09	25		300#	7.62	7.62	8.50	8.50	1.69	5.12	16	17	
1 1/4"	DV/BRZ	4.12	10.00	2.62	7.09	21	150#	DV/BRZ	CS/SS	7.25	7.25	10.00	10.75	2.62	7.09	26	34
	CS/SS	4.81	11.00	2.25	7.09	31		300#	8.75	7.75	10.00	10.75	2.62	7.09	28	37	
2"	DV/BRZ	4.50	10.25	2.75	7.09	26	150#	DV/BRZ	CS/SS	7.87		10.00		2.62	7.09	28	
	CS/SS	5.50	11.00	2.75	7.09	35		300#	8.37		10.00		2.62	7.09	31		
1 1/2"	DV/BRZ	8.75	8.75	10.25	11.22	2.31	7.09	42	46								
	CS/SS	10.25	9.25	10.25	11.22	2.31	7.09	45	52								
2"	DV/BRZ	10.00	10.00	10.25	11.42	2.75	7.09	46	50								
	CS/SS	10.50	10.50	10.25	11.42	2.75	7.09	49	55								

Ⓢ NOT ANSI STD.
Ⓢ IFE ONLY



MK50 & 60

SPECIFICATION DATA	
CUSTOMER _____	SERIAL No. _____
ORDER No. _____	TAG No. _____
VALVE TYPE _____	QTY. _____
BODY _____	
END CONN. _____	MAX. ΔP _____
INLET PRESS. _____	SET PT. _____
PRESS. RANGE _____	
VALVE ACTION: RISE IN PRESSURE TO	<input type="checkbox"/> OPEN
	<input type="checkbox"/> CLOSE
VALVE SEAT _____	Cr _____
MISC. _____	
CERTIFIED _____	DATE _____

RICHARDS INDUSTRIES
CINCINNATI, OHIO
U.S.A.
VALVE GROUP

1/2-2" MARK 50 & 60
BACK PRESSURE REGULATOR & PRESSURE REDUCING VALVE.

DRAWN BY: JLA	DATE: 1/4/96
CHECKED BY: _____	DATE: _____

MK50/60